

Number	KIP-15983/G	Scope	Regulation (EU) 2016/426
Issue date	16-10-2018	Module	B
Expire date	15-10-2028		
PIN	0476CQ0134	Report	140700134/7
Replaces	KIP-15736/G	Page	1 of 2

## EU TYPE-EXAMINATION CERTIFICATE

### Kiwa Cermet Italia declares that the products type:

Central heating condensing boilers

Trade mark: **ROBUR**

Models: *as specified in the Annex 1*

Placed on the market by **ROBUR S.p.A.**

Via Parigi 4/6, 24040 Verdellino/Zingonia  
(BG) - Italy

meet the essential requirements as described in the

### Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Appliance type: B<sub>23</sub>, B<sub>33</sub>, C<sub>13</sub>, C<sub>33</sub>, C<sub>43</sub>, C<sub>53</sub>, C<sub>63</sub>, C<sub>83</sub>, C<sub>93</sub>,  
C<sub>13X</sub>, C<sub>33X</sub>, C<sub>43X</sub>, C<sub>53X</sub>, C<sub>63X</sub>, C<sub>83X</sub>, C<sub>93X</sub>

Countries: AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR,  
HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO,  
SE, SI, SK, TR

Related to the following gas groups: *as specified in the Annex 1*

The assessment test have been performed using the following standards as guidelines:

EN 15502-1:2012 + A1:2015, EN 15502-2-1:2012


The validity of this certificate can be verified on request at the following e-mail address: [info@kiwa.it](mailto:info@kiwa.it)  
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Chief Operating Officer  
Giampiero Belcredi



SGQ N° 007A  
SGA N° 010D  
PRD N° 069B  
FSM N° 004I  
PRS N° 089C





Number	KIP-15983/G	Scope	Regulation (EU) 2016/426
Issue date	16-10-2018	Module	B
Expire date	15-10-2028		
PIN	0476CQ0134	Report	140700134/7
Replaces	KIP-15736/G	Page	2 of 2

## EU TYPE-EXAMINATION CERTIFICATE

### ANNEX 1

#### Models:

R1K 24/B HR, R2K 24 HR, R1K 25 HR, R1K 28/B HR, R1K 34 HR,  
R1K 34/B HR, R2K 34 HR, Caldaria 35 Condensing+, Caldaria 35 Condensing+ ACS,  
Caldaria 55.1 Condensing+, Caldaria 75.1 condensing+, Caldaria 100.2 condensing+

#### Are approved for the following gas groups

Group	mbar
E	20
H	20;25
L	25

Group	mbar
LL	20
Esi,E(S)	20/25
E(R)	20/25

Group	Mbar
B/P	30; 37; 50
P	30; 37; 50
EK	20/25

#### Model:

R1K 18 HR

#### Is approved for the following gas groups

Group	mbar
E	20
H	20;25
L	25

Group	mbar
LL	20
Esi,E(S)	20/25
E(R)	20/25

Group	Mbar
B/P	30; 37; 50
P	30; 37; 50

*The above gas groups can be combined according to the standard EN437:2009 and national situation of countries.*